

Committee Meeting Attendance & Report of Meeting

Date: 10-29-2025

Time: 2:30 / 3:50

Committee Name: WATER / SEWER



Committee Members

Present

1. TONY WRIGHT (Chairmen)
2. ALENE BLADE
3. _____

☒
☒
☐

Name(s) of others in Attendance:

1. BARB HEALY
2. ROGER NUXOLL
3. JAKE PETERS
4. _____
5. _____
6. _____
7. _____
8. _____

Nature of Meeting: SEWER ISSUES / UPGRADES ON THE EAST SIDE OF GREENUP

Meeting Report: OUR 2 MAIN USERS OF OUR SEWER SYSTEM ON THE EAST SIDE OF TOWN ARE OVER LOADING OUR SYSTEM BY VOLUME AND MISCELLANEOUS DE BRIS. WE HAVE SEVERAL ISSUES BEING THE SIZE OF OUR LINES AND THE FALL OF THE LINES. WE HAVE A FALL RATE OF .2 AND IT SHOULD BE .4 . WE HAVE LINES THAT ARE NOT PRESANT DUE TO TOTAL COLLAPSE OF THE LINE. RE-ROUTING OF LINES WAS DISCUSSED AS WELL AS SMOKE TESTING TO FIND ILLEGAL TAPS AND BRICK MAN HOLES THAT ARE TAKING IN GROUNDWATER. SEWER LININGS WYB ALSO TALKED ABOUT. THE FOOTINGS OF THE OLD WATER TOWER WAS DISCUSSED AS THEY ARE DETERIORATING. ALSO DISCUSSED WAS THE WATER LINE GONGS NORTH ON Route 130. THE STATE IS CURRENTLY REVIEWING THOSE PLANS. MEETING ADJOURNED AT 3:50 pm

Committees Recommendation: FARNSWORTH WILL START SEEKING EPA/USDA LOANS FOR FINANCING NEEDED IMPROVEMENTS. THEY WILL ALSO START DOING DEPTH MEASUREMENTS OF OUR LINES. WE INSTRUSTED JAKE PETERS TO GET WITH BAT DRAINAGE AND GET IT FIXED ASAP. GET BIDS FOR FIXING THE WATER TOWER FOOTINGS.

Approved by: _____ (Mayor)

Please submit to the City Clerk for record keeping. Recording of Committee Meetings is the responsibility of the Chairman of the Committee or a Committee member appointed by the Chairman or the City Clerk if in attendance

Committee Meeting Attendance & Report and all information should be turned in to the City Clerk no later than 5 business days after the meeting date